EXPERIMENTAL STUDY ON THE SMOKE TEMPERATURE DISTRIBUTION ALONGSIDE THE LINING IN TUNNEL FIRES

by

Feng WANG, Yu WANG, Yubing HUANG, and Qixiang YAN*

Key Laboratory of Transportation Tunnel Engineering, Ministry of Education, School of Civil Engineering, Southwest Jiaotong University, Chengdu, China

Original scientific paper https://doi.org/10.2298/TSCI190114273W

Tunnel fire temperature is a key factor for tunnel structural safety and evacuation. This study aimed to investigate the smoke temperature distribution alongside the lining across the section and effects of pool sizes and fuels on it through a series of small-scale experiments. The results showed the heat release rates of diesel were significantly lower than gasoline's when they had the same pool size and volume. Nevertheless, the duration of diesel combustion increased obviously. As a result, the maximum smoke temperature under the ceiling for gasoline was significantly higher than diesel's. The results were subsequently adopted to compare with other test results and illustrated a similar result. The initial temperature rising rates for gasoline pool fires were shown to agree well with the standardized temperature curves, but they were significantly lower for diesel pool fires. Two exponential correlations on vertical temperature distribution were provided, respectively, for gasoline and diesel fires. These findings are expected to be useful for the design of the thermal boundary on the lining in tunnel fires.

Key words: tunnel fire, smoke temperature distribution, lining, fuel, experiments

Introduction

Tunnel fires and thermal effect on environment and structure have already been an important issue in tunnel [1, 2]. Several occurred tunnel fires over the past two decades resulted in severe destruction to tunnel lining structure. For instance, Mont Blanc tunnel fire between France and Italy in 1999, causing the tunnel closed for 3 years. Tauern tunnel fire in Austria in 1999, causing the tunnel closed for 3 months, Yanhou tunnel fire in China in 2014 burned for 2 days, causing serious damage to the tunnel lining of 400 m, and it was closed for 7 months [3, 4]. The tunnel lining structure safety accordingly attracted much attention when exposed to fire. Typically, the impact of thermal exposure on the tunnel lining structure is believed to be strongly dependent of the maximum temperature and its duration in tunnel fires. Nevertheless, our current concern is the smoke temperature distribution alongside the lining across the section. Because tunnel lining is essentially exposed to an inconsistent fire temperature load, causing the thermal and mechanical behaviours of tunnel lining to be different.

So far, the thermal exposure in tunnel fires was widely evaluated by the use of standardized fire temperature curves, such as ISO 834, the hydrocarbon (HC) curve, and RWS curve [5-13]. However, it should be noted that these standardized temperature-time curves were usually based on extreme fire loads. For instance, RWS curve was proposed according to a tank-

^{*} Corresponding author, e-mail: yanqixiang@swjtu,edu,cn

er with 50 m³ gasoline on fire in a road tunnel. As a result, the maximum temperatures of these curves were mostly higher than 1000 °C. Tunnel engineers usually adopted these standardized temperature-time curves as temperature load to assess the safety of the tunnel lining. In practice, the use of these fire loads would generally overshoot the tunnel fire load [14]. Due to this fact, PIARC reported the maximum temperature based on the heat release rate in tunnel fires [5]. Some improved models predicting the maximum temperature beneath the tunnel ceiling were subsequently proposed with consideration of heat release rate (HRR), ventilation speed and tunnel size as well. Initially, Kurioka *et al.* [15] suggested an empirical equation to predict the maximum excess temperature which showed a good agreement with the full-scale test result conducted by Hu *et al.* [16]. Li *et al.* [17] found this model only valid for the prediction of a forced ventilation case in tunnel fires. Because the maximum excess temperature beneath the ceiling reached infinity in his model, when the ventilation speed approached zero. He accordingly proposed an improved model, as eq. (1). Afterwards, Li and Ingason [18] made further job on this model which shows two regions. Each was divided into two sub-regions again:

$$\Delta T_{\max} = \begin{cases} \frac{Q}{Vr^{1/3}H_{ef}^{5/3}}, & V' > 0.19\\ 17.5 \frac{Q^{2/3}}{H_{ef}^{5/3}}, & V' \le 0.19 \end{cases}$$
(1)

where

$$V' = \frac{V}{\left(\frac{Q_c g}{r\rho_0 c_p T_0}\right)^{1/3}}$$

where ΔT_{max} is the maximum excess temperature beneath the ceiling, Q – the total HRR, V – the ventilation velocity, r – the radius of the fire source, H_{ef} – the effective tunnel height, Q_c – the convective heat release rate, g – the gravitational acceleration, ρ_0 – the ambient density, c_p is the thermal capacity of air, T_0 is the ambient temperature.

In addition, there are a lot of studies to focus on sensitivity analysis of the maximum temperature and its spread in tunnel fires, including the influence of tunnel curvature, sloping, blockage, cross-section, ventilation velocity, natural smoke exhaust shaft and fire suppression [19-31]. Recently, extensive studies on transverse fires in a tunnel have further been reported through full-scale tests, model-scale experiments and numerical simulation. Much concern concentrated on effects of transverse fires on the maximum temperature, smoke movement, flame characteristics, air entrainment, and burning rate [32-39].

The aforementioned studies allow a better understanding of fire behaviour in tunnels. However, it should be noted that there has never been reported on the smoke temperature distribution alongside the lining across the section in tunnel fires. This is of particularly importance for the thermal analysis of tunnel lining structure. Accordingly, there is a clearly need to understand the maximum smoke temperature distribution on the tunnel lining across the section in tunnel fires. In the light of this, the objective of this paper is to present a detailed small-scale experimental results on HRR, temperature histories and the maximum temperature distribution on the tunnel lining across the section in tunnel fires. Pool sizes and fuel categories would be fully investigated and discussed. These findings are expected to be useful for the design of the thermal boundary on the lining in tunnel fires.

Experimental arrangement

The experiments were undertaken in a small-scale tunnel model with a scale ratio of 1:16. The model was 8.5 m long, 0.6 m wide and 0.44 m high, as shown in fig. 1. A arched ceiling, along with straight walls was imposed upon the cross-section. The model was made of stainless steel of 2 mm thickness, covered by 30 mm thick felt and sheet iron, as seen in fig. 2. The test section was within a middle section of 4.5 m length, where the fireproof glass was installed on one side straight wall instead of stainless steel.



Figure 1. The model tunnel, unit [mm]

The tests were conducted using pool fires. Gasoline and diesel were chosen as the fuels in the present study, because they were the most popular fuels in vehicles. The pool was located in the middle of the cross-section with a height of 20 mm from the ground. Two pool sizes were employed to assess the effect of pool sizes, as shown in tab. 1. The heat release rates were evaluated both according to the study of Hu et al. [16] and by the use of fuel burning rate in experiments. The Froude modeling was subsequently applied into the physical scale analysis. Through meeting the Froude number conservation, the relationships between model and full-scale



Figure 2. Schematic of experiment apparatus

can be simplified to obtain the required scaling laws, as shown in eqs. (2) and (3). Where L denotes the size and the subscript *m* represents the model tunnel and *f* is the full-scale:

$$\frac{Q_m}{Q_f} = \left(\frac{L_m}{L_f}\right)^{5/2} \tag{2}$$

$$\frac{V_m}{V_f} = \left(\frac{L_m}{L_f}\right)^{1/2} \tag{3}$$

Measurements of smoke temperature were arranged on the fire source section using K-type thermocouples. Each thermocouple was positioned 20 mm away from the tunnel lining. The fuel mass was measured by an electronic scale. Flame and smoke layering behaviors were recorded from the front view using a digital cameras (DV), as shown in fig. 1.

Results and discussion

Heat release rate

The HRR is usually used to understand the fire intensity and speculate the maximum temperature. Accordingly, the HRR is firstly analyzed in this study. It is widely evaluated by the fuel mass loss rate using eq. (4) [33], where the mass loss rate, \dot{m} , is adopted by measuring the fuel mass loss per second. The effective heat of combustion is expressed by $\Delta H_{c,\text{eff}}$. The combustion efficiency, η , of pool fires is suggested 0.75 by Hu *et al.* [40]. In their study, they found the combustion efficiency of pool fires in a tunnel was typically 0.75 by the oxygen consumption and the mass loss rate experimentally. In this study, $\Delta H_{c,\text{eff}}$ is taken as 43700 KJ/kg for gasoline and 44400 KJ/kg for diesel, as given in SFPE handbook [41].

$$Q = \eta \dot{m} \Delta H_{c,\text{eff}} \tag{4}$$

Figure 3 gives the typical HRR histories for both fuels. It can be seen that all the HRR histories have a relatively steady stage following a rapid rise. The averaged steady HRR are listed in tab. 1. The HRR of the gasoline fire is observed to be significantly higher than die-



Figure 3. Typical HRR for both fuels Table 1. Experimental condition and HRR

sel's, being almost three times higher when they have the same volume. From eq. (4), it is easy to understand that the main cause is the difference in the burning rate of both fuels. As is well-known that the burning rate of the gasoline is normally greater due to its strong volatility. The difference in the duration of combustion can also explain it. The combustion duration of the diesel is significantly longer than gasoline's. In addition, It can also be found that the HRR in the case of pool size B is more than twice of that in pool size A, where the area increases by 69% compared to size A.

| Test | Pool size | Fuel height | Duration of | Range of HRR | Averaged |
|----------|-----------|-------------|----------------|---------------|----------|
| category | [mm×mm] | [mm] | combustion [s] | in model [kW] | HRR [kW] |
| Gasoline | A:100×100 | 40 | 925 | 10.69-14.25 | 12.47 |
| | B:130×130 | | 675 | 25.43-35.47 | 30.45 |
| Diesel | A:100×100 | 40 | 2655 | 2.77-5.15 | 3.96 |
| | B:130×130 | | 1830 | 8.79-11.2 | 10.20 |

Temperature history and maximum smoke temperature under ceiling

Temperature history is usually designed for the thermal boundary condition on the lining. There are several standardized temperature curves widely used for the safety assessment of tunnel lining. But it is noted that these standardized temperature curves mostly overestimate the thermal load in tunnel fires. As a consequence, there is a clear need to understand the real temperature history.

3704

Figures 4 and 5 show the temperature histories from the middle thermocouple under the ceiling, as well as two standardized temperature curves, namely HC and RABT-ZTV curves. It can be found all of the maximum temperatures from this test are significantly lower than the standardized temperature curves. This is easily understood. From PIARC report, the temperature over 1000 °C means the HRR would be greater than 100 MW in tunnel fires [5]. Clearly, the HRR are far less than this value in this study. In the other hand, the temperature rises at different rates. For gasoline pool fires, the initial temperatures rise at the same rate for size A and size B, and the temperature-rising rates agree well with the standardized temperature curves. In the case of diesel pool fires, the temperature-rising rates are significantly lower than the standardized temperature curves. Furthermore, there is a gentler temperature-rising for size A.



Figure 4. Temperature histories in gasoline pool fires

Figure 6 gives the maximum temperatures from this test and other test results, together with Li et al. 's model [17, 18, 42]. The comparison of the maximum temperatures are shown an acceptable agreement with Li's model. However, it also needs to be noted that our test results are slightly lower than Li's model. The possible reason is that Li's model is mainly derived from the light-weight fuel. This could avoid large amount of soot in fires. As a result, the maximum temperature under ceiling is completely affected by the flame behavior. Conversely, smoke behavior could be the main cause for gasoline or diesel pool fires in this test. Smoke temperature is essentially slightly lower than the flame temperature.



Figure 5. Temperature histories in diesel pool fires



Figure 6. The maximum excess temperature beneath the ceiling [17, 18, 42]

Figures 7 and 8 show the typical smoke layering and flame behavior in gasoline and diesel pool fires. A heavy smoke layer with a large amount of soot is found under the tunnel ceiling and it gets thicker with the increase of pool size. The substantial soot is assumed to prevent the flame reaching the ceiling, and the flame is submerged in the smoke layer. Actually, the flame does not get fully-developed vertically, and is constrained to spread transversely. The flame width become wider with the increase of pool size. As a consequence, the maximum

Wang, F., et al.: Experimental Study on the Smoke Temperature Distribution Alongside ... THERMAL SCIENCE: Year 2019, Vol. 23, No. 6A, pp. 3706-3710



Figure 7. Smoke layer and flame in gasoline pool fires; (a) size A, (b) size B



Figure 8. Smoke layer and flame in diesel pool fires; (a) size A, (b) size B

temperature under the ceiling is strongly dependent of the smoke temperature. Additionally, the flame width for the gasoline pool fire is significantly greater than the corresponding diesel pool fire due to its increasing HRR.

Smoke temperature distribution along side the lining

The maximum smoke temperature in this study has been shown a not bad result through comparing with Li's model. Nevertheless, it is necessary to understand the smoke temperature distribution in order to assess the thermal boundary condition on the lining, rather than the top ceiling. The smoke temperature distributions alongside the lining across the section for various pool sizes are given in fig. 9. Clearly, the temperature upon the fire is normally larger than the others, producing a hump-shaped profile. The hump of temperature become flat gradually in a larger size pool. It means the high temperature range extends transversely. It also needs to be noted that the detailed temperatures closed to the both sidewalls cannot be observed very well. In addition, from the point of temperature values, the smoke temperature for gasoline is significantly higher than diesel's. This phenomena is a consequence of the HRR behaviors.

3706



All results presented so far can already help to understand effects of fuel categories and pool sizes on the temperature and its distribution in tunnel fires. Before attempting to provide a simple and useful expression on the smoke temperature distribution, it would clearly be advantageous and necessary to establish a non-dimensional parameter to characterize the temperature.

In fact, Alpert [43] previously proposed an empirical equation on the correlations between the maximum temperature and the radial distance under an unconfined ceiling.

$$\Delta T_{r,\max} = 5.38 \frac{\left(\frac{Q}{r}\right)^{2/3}}{H}, \qquad r > 0.18H$$
(5)

Obviously, this is not applicable to a confined ceiling. An exponential expression was subsequently presented by Delichatsios [44] based on a fully developed 1-D channeled ceiling flow.

$$\frac{\Delta T_r}{\Delta T_{0,\max}} \left(\frac{l}{H}\right)^{1/3} = \beta \exp\left\{-6.67 \operatorname{St} \frac{r}{H} \left(\frac{l}{H}\right)^{\frac{1}{3}}\right\}, \quad r > H$$
(6)

It is noted that this correlation is only used for r > H. In other words, this fits the longitudinal temperature distribution. Even though, this exponential function is found to be still suitable for transverse temperature distributions. Ji *et al.* [45] proposed an empirical correlation through a series of experiments in a model subway station, which can be expressed:

$$\frac{\Delta T_{r,\max}}{\Delta T_{\infty,\max}} = 0.299 \exp\left(-0.793 \frac{r}{H}\right) + 1 \tag{7}$$

Note they adopted the maximum temperature rise without the impact of the sidewall to normalize the maximum temperature. As a consequence, this ratio should be greater than 1.

However, it needs to be noted these above radial maximum temperature expressions cannot predict the smoke temperature distribution alongside the lining. The smoke temperature distribution is necessary to analyze the thermal load on the lining. To do this, constructing such a parameter and normalizing the vertical temperature with the maximum temperature under

3707

ceiling gives $\Delta T_{h,\max}/\Delta T_{H,\max}$. The ratio of vertical height and tunnel height h/H is employed instead of radial position.

Based on the radial maximum temperature distribution correlations proposed previously, We suppose this exponential correlation can still be extended to the vertical smoke temperature distribution and impose it:

$$\frac{\Delta T_{h,\max}}{\Delta T_{H,\max}} = \alpha \exp\left(\beta \frac{h}{H}\right) \tag{8}$$

Figures 10(a) and 10(b) show the vertical maximum temperature distributions for gasoline and diesel pool fires, respectively. The vertical temperature distribution can be found to be correlated by an exponential function of eq. (8), but with different values in these coefficients for gasoline and diesel.



Figure 10. Vertical temperature distributions for pool fires of size A and B; (a) gasoline, (b) diesel

Typically, the correlation can be expressed for gasoline:

$$\frac{\Delta T_{h,\max}}{\Delta T_{H,\max}} = 0.136 \exp\left(1.99\frac{h}{H}\right) \tag{9}$$

The corresponding for diesel can be expressed:

$$\frac{\Delta T_{h,\max}}{\Delta T_{H,\max}} = 0.227 \exp\left(1.48 \frac{h}{H}\right) \tag{10}$$

The maximum temperature ratio for diesel is shown to be obviously higher than that for gasoline. For instance, the ratio is nearly 0.26 at h/H = 0.1 for diesel, being significantly higher than the corresponding values of 0.16 for gasoline. It means the thermal diffusion along-side the lining in diesel fires is stronger than that in gasoline fires.

Conclusions

An experimental study was developed to investigate the smoke temperature distribution alongside the lining across the section with gasoline and diesel pool fires in a tunnel. Firstly, the HRR behaviors are shown to be significantly different for gasoline and diesel. The duration of diesel combustion is almost three times than gasoline when they have the same volume. However, the HRR values of diesel are obviously lower than gasoline's. Correspondingly, the Wang, F., *et al.*: Experimental Study on the Smoke Temperature Distribution Alongside ... THERMAL SCIENCE: Year 2019, Vol. 23, No. 6A, pp. 3709-3710

maximum smoke temperature for gasoline is significantly higher than diesel's. Additionally, the temperature history is illustrated, the temperature-rising rate of gasoline fire agrees well with the standardized temperature curves and significantly higher than the diesel fire. Furthermore, two correlations on the vertical temperature distribution are provided, respectively, for gasoline and diesel according to these experimental results. These findings are helpful for designing the smoke temperature distribution on the lining in tunnel fires.

Acknowledgment

The authors gratefully acknowledge that the work reported in this paper is sponsored by the Natural Science Foundation of China through Grant No. 51678493 and the Fundamental Research Funds for the Central Universities through Grant No. 2682018CX02.

References

- Ricky, C., A Review of Tunnel Fire Research from Edinburgh, *Fire Safety Journal*, 105 (2019), Apr., pp. 300-306
- [2] Wang, F., *et al.*, Thermal Analysis and Air Temperature Prediction in TBM Construction Tunnels, *Applied Thermal Engineering*, *158* (2019), July, 113822
- [3] Lonnermark, A., On the Characteristics of Fires in Tunnels, Department of Fire Safety Engineering, Ph. D. thesis, Lund University, Lund, Sweden, 2005
- [4] Wu, L., The Fire Fighting Design of Highway Tunnel Based on Yanhou Tunnel Accident, *Fire Science and Technology*, 33 (2014), 11, pp. 1284-1287
- [5] ***, PIARC, Fire and Smoke Control in Road Tunnels, PIARC Technical Committee C5 Road Tunnel, 1999
- [6] ***, BS EN 1991-1-2, Eurocode 1: Actions on Structures, Part 1-2: General Actions-Actions on Structures Exposed Ffire, 2002
- ***, ISO 834-1, Fire-Resistance Tests-Elements of Building Construction-Part 1: General Requirements, International Organization for standardization, 1999
- [8] Caner, A., et al., Structural Fire Performance of Concrete and Shortcrete Tunnel Liners, Journal of Structural Engineering, 131 (2005), 12, pp. 1920-1925
- [9] Caner, A., Boncu, A., Structural Fire Safety of Circular Concrete Railroad Tunnel Linings, *Journal of Structural Engineering*, 135 (2009), 9, pp. 1091-1092
- [10] Pichler, C., et al., Safety Assessment of Concrete Tunnel Linings under Fire Load, Journal of Structural Engineering, 132 (2006), 6, pp. 961-969
- [11] Yan, Z., et al., Full-Scale Fire Tests of RC Metro Shield TBM Tunnel Linings, Construction and Building Materials, 36 (2012), Nov., pp. 484-494
- [12] Yan, Z., et al., Behavior of Reinforced Concrete and Steel Fiber Reinforced Concrete Shield TBM Tunnel Linings Exposed to High Temperatures, Construction and Building Materials, 38 (2013), Jan., pp. 610-618
- [13] Yan, Z., et al., Experimental Study of Tunnel Segmental Joints Subjected to Elevated Temperature, Tunnelling and Underground Space Technology, 53 (2016), Mar., pp. 46-60
- [14] Wang, F., et al., The Effects of the Passive Fire Protection Layer on the Behavior of Concrete Tunnel Linings: A Field Fire Testing Study, *Tunnelling and Underground Space Technology*, 69 (2017), Oct., pp. 162-170
- [15] Kurioka, H., et al., Fire Properties in Near Field of Square Fire Source with Longitudinal Ventilation in Tunnels, Fire Safety Journal, 38 (2003), 4, pp. 319-340
- [16] Hu, L. H., et al., On the Maximum Smoke Temperature under Ceiling in Tunnel Fires, Tunnelling and Underground Space Technology, 21 (2006), 6, pp. 650-655
- [17] Li, Y. Z., et al., The Maximum Temperature of Buoyancy-Driven Smoke Flow Below the Ceiling in Tunnel Fires, Fire Safety Journal, 46 (2011), 4, pp. 204-210
- [18] Li, Y. Z., Ingason, H., The Maximum Ceiling Gas Temperature in a Large Tunnel Fire, *Fire Safety Journal*, 48 (2012), Feb., pp. 38-48
- [19] Tang, F., et al., A Study on the Maximum Temperature of Ceiling Jet Induced by Rectangular-Source Fires in a Tunnel Using Ceiling Smoke Extraction, International Journal of Thermal Sciences, 127 (2018), May, pp. 329-334
- [20] Wang, F., et al., Numerical Study on Fire Smoke Movement and Control in Curved Road Tunnels, Tunnelling and Underground Space Technology, 67 (2017), Aug., pp. 1-7

- [21] Lee, S. R., Ryou, H. S., A Numerical Study on Smoke Movement in Longitudinal Ventilation Tunnel Fires for Different Aspect Ratio, *Building and Environment*, 41 (2006), 6, pp. 719-725
- [22] Chow, W. K., et al., Longitudinal Ventilation for Smoke Control in a Tilted Tunnel by Scale Modeling, Tunnelling and Underground Space Technology, 25 (2010), 2, pp. 122-128
- [23] Chow, W. K., et al., Smoke Movement in Tilted Tunnel Fires with Longitudinal Ventilation, Journal of Fire Safety, 75 (2015), July, pp. 14-22
- [24] Lee, Y. P., Tsai K. C., Effect of Vehicular Blockage on Critical Ventilation Velocity and Tunnel Fire Behavior in Longitudinally Ventilated Tunnels, *Fire Safety J.*, 53 (2012), Oct., pp. 35-42
- [25] Gannouni, S., Maad Rejeb, B., Numerical Study of the Effect of Blockage on Critical Velocity and Back Layering Length in Longitudinally Ventilated Tunnel Fires, *Tunnelling and Underground Space Technol*ogy, 48 (2015), Apr., pp. 147-155
- [26] Vega, M. G., et al., Numerical 3D Simulation of a Longitudinal Ventilation System: Memorial Tunnel Case, Tunnelling and Underground Space Technology 23 (2008), 5, pp. 539-551
- [27] Betta, V., et al., Fluid Dynamic Performances of Traditional and Alternative Jet Fans in Tunnel Longitudinal Ventilation Systems, *Tunnelling and Underground Space Technology*, 25 (2010), 4, pp. 415-422
- [28] Se Camby, M. K., et al., Impact of Location of Jet Fan on Airflow Structure in Tunnel Fire, *Tunnelling and Underground Space Technology*, 27 (2012), 1, pp. 30-40
- [29] Tang, F., et al., Characterization of Buoyant Flow Stratification Behaviors by Richardson (Froude) Number in a Tunnel Fire with Complex Combination of Longitudinal Ventilation and Ceiling Extraction, *Appl., Therm., Eng., 110* (2017), Sept., pp. 1021-1028
- [30] Tang, F., et al., Effect of Blockage-Heat Source Distance on Maximum Temperature of Buoyancy-Induced Smoke Flow Beneath Ceiling in a Longitudinal Ventilated Tunnel, Int. J. Heat Mass. Tran., 109 (2017), June, pp. 683-688
- [31] Fan, C., *et al.*, Effects of Fire Location on the Capacity of Smoke Exhaust from Natural Ventilation Shafts in Urban Tunnels, *Fire and Materials, 42* (2018), 8, pp. 974-984
- [32] Wang, F., Wang, M., A Computational Study on Effects of Fire Location on Smoke Movement in a Road Tunnel, *Tunnelling and Underground Space Technology*, 51 (2016), Jan., pp. 405-413
- [33] Ji, J., et al., Experimental Investigation on Influence of Different Transverse Fire Locations on Maximum Smoke Temperature under the Tunnel Ceiling, Int., J., Heat Mass Transf., 55 (2012), 17-18, pp. 4817-4826
- [34] Fan, C. G., et al., Experimental Study on Transverse Smoke Temperature Distribution in Road Tunnel Fires, Tunn., Undergr., Space Technol., 37 (2013), Aug., pp. 89-95
- [35] Gao, Z. H., et al., Influence of Sidewall Restriction on the Maximum Ceiling Gas Temperature of Buoyancy-Driven Thermal Flow, Energy Build, 84 (2014), Dec., pp. 13-20
- [36] Ji, J., et al., Experimental Study of Non-Monotonous Sidewall Effect on Flame Characteristics and Burning Rate of n-Heptane Pool Fires, Fuel, 145 (2015), Apr., pp. 228-233
- [37] Gao, Z., et al., Experimental Study of Tunnel Sidewall Effect on Flame Characteristics and Air Entrainment Factor of Methanol Pool Fires, Appl., Therm., Eng., 102 (2016), June, pp. 1314-1319
- [38] Zhou, T., et al., Influence of Constraint Effect of Sidewall on Maximum Smoke Temperature Distribution under a Tunnel Ceiling, Appl., Therm., Eng., 112 (2017), Feb., pp. 932-941
- [39] Tang, F., et al., Studies on Ceiling Maximum Thermal Smoke Temperature and Longitudinal Decay in a Tunnel Fire with Different Transverse Gas Burner Locations, Appl., Therm., Eng., 110 (2017), Jan., pp. 1674-1681
- [40] Hu, L. H., et al., Experimental Studies on Fire-Induced Buoyant Smoke Temperature Distribution Along Tunnel Ceiling, Building and Environment, 42 (2007), 11, pp. 3905-3915
- [41] Morgan, J. H., SFPE Handbook of Fire Protection Engineering, 5th ed. SFPE, Greenbelt, Md, USA, 2016
- [42] Ingason, H., et al., Runehamar Tunnel Fire Tests, Fire Safety Journal, 71 (2015), Jan., pp. 134-149
- [43] Alpert, R. L., Calculation of Response Time of Ceiling-Mounted Fire Detectors, *Fire Technology*, 8 (1972), 3, pp. 181-195
- [44] Delichatsios, M. A., The Flow of Fire Gases under a Beamed Ceiling, Combustion Flame, 43 (1981), pp. 1-10
- [45] Ji, J., et al., A Simplified Calculation Method on Maximum Smoke Temperature under the Ceiling in Subway Station Fires, *Tunnelling and Underground Space Technology*, 26 (2011), 3, pp. 490-496

Paper submitted: January 14, 2019 Paper revised: May 27, 2019 Paper accepted: June 6, 2019 © 2019 Society of Thermal Engineers of Serbia Published by the Vinča Institute of Nuclear Sciences, Belgrade, Serbia. This is an open access article distributed under the CC BY-NC-ND 4.0 terms and conditions